

•
•
•
•
•

1505 East High Street
Jefferson City, Missouri 65101
Telephone (573) 659-9078
Facsimile (573) 659-9079

GREDELL Engineering Resources, Inc.

Sikeston Board of Municipal Utilities Sikeston Power Station Fly Ash Pond Inflow Design Flood Control System Plan

• *Prepared for:* • • • • •



**Sikeston Power Station
1551 West Wakefield Avenue
Sikeston, MO 63801**

April 2018

**Sikeston Board of Municipal Utilities
Sikeston Power Station
Fly Ash Pond
Inflow Design Flood Control System Plan**

April 2018

Table of Contents

| | |
|---|-----------|
| PROFESSIONAL ENGINEER’S CERTIFICATION..... | 1 |
| 1.0 INTRODUCTION..... | 2 |
| 1.1 §257.82(a) and (b) – Hydrologic and Hydraulic Capacity Requirements for CCR Surface Impoundments | 2 |
| 1.2 §257.82(c) – Inflow Design Flood Control System Plan..... | 2 |
| 1.3 §257.3-3 – Surface Water | 3 |
| 2.0 POND DESCRIPTIONS..... | 4 |
| 2.1 Fly Ash Pond Influent and Discharge Systems | 4 |
| 2.2 Bottom Ash Pond Influent and Discharge Systems..... | 4 |
| 2.3 Settling Pond Influent and Discharge Systems | 5 |
| 2.4 Process Waste Pond Influent and Discharge Systems | 6 |
| 3.0 INFLOW DESIGN FLOOD..... | 8 |
| 3.1 Fly Ash Pond Hazard Potential Classification | 8 |
| 3.2 Fly Ash Pond Inflow Design Flood | 8 |
| 4.0 INFLOW DESIGN FLOOD CONTROL SYSTEM | 9 |
| 4.1 Fly Ash Pond Inflow and Outflow | 9 |
| 4.2 Bottom Ash Pond Inflow and Outflow..... | 9 |
| 4.3 Settling Pond Inflow and Outflow | 10 |
| 4.4 Process Waste Pond Inflow and Outflow | 11 |
| 4.5 Clean Water Act Surface Water Requirements..... | 11 |
| 5.0 RECOMMENDATIONS..... | 13 |
| 6.0 PERIODIC PLAN PROCEDURES..... | 14 |
| 7.0 PLAN AMENDMENTS..... | 15 |
| 8.0 MISCELLANEOUS REQUIREMENTS | 16 |

List of Appendices

Appendix A Figures

Appendix B Hydraflow Report – 100-year Design Flood

PROFESSIONAL ENGINEER'S CERTIFICATION

40 CFR 257.82(c) Inflow Design Flood Control System Plan

I, John N. Browning, P.E., a professional engineer licensed in the State of Missouri, hereby certify in accordance with 40 CFR 257.82(c)(5) that the inflow design flood control system plan for the Sikeston Board of Municipal Utilities, Sikeston Power Station, Fly Ash Pond meets the requirements of 40 CFR 257.82(c)(1) as found in federal regulation 40 CFR 257, Subpart D – Standards for the Disposal of Coal Combustion Residuals in Landfills and Surface Impoundments and has been prepared using good engineering and environmental judgement and standard accepted practices.

Name: John N. Browning, P.E.

Signature: 

Date: 04/14/2018

Registration Number: E-20769

State of Registration: Missouri



1.0 INTRODUCTION

In accordance with the scope of services outlined in the Sikeston Board of Municipal Utilities (SBMU) Work Order No. 15 dated January 22, 2018, GREDELL Engineering Resources, Inc. (Gredell Engineering) developed an inflow design flood control system plan for the SBMU, Sikeston Power Station (SPS) Fly Ash Pond, a coal combustion residual (CCR) surface impoundment. The purpose of this inflow design flood control system plan is document how the inflow design flood control system has been designed and constructed to meet the requirements of the Federal CCR Rule, section (§) 40 CFR 257.82. Excerpts from the Federal CCR Rule, §257.82(a)-(c), describing the hydrologic and hydraulic capacity requirements of CCR surface impoundments and the required contents of this inflow design flood control system plan are provided for reference below. §257.3-3 describing the surface water protection requirements is also provided for reference below.

1.1 §257.82(a) and (b) – Hydrologic and Hydraulic Capacity Requirements for CCR Surface Impoundments

Excerpts from §257.82(a) and (b), which regards the hydrologic and hydraulic capacity requirements for CCR surface impoundments completed by Gredell Engineering, are provided for reference below.

(a)(1) The inflow design flood control system must adequately manage flow into the CCR unit during and following the peak discharge of the inflow design flood specified in paragraph (a)(3) of this section.

(a)(2) The inflow design flood control system must adequately manage flow from the CCR unit to collect and control the peak discharge resulting from the inflow design flood specified in paragraph (a)(3) of this section.

(a)(3) The inflow design flood is: for a high hazard potential CCR surface impoundment, the probable maximum flood; for a significant hazard potential CCR surface impoundment, the 1,000-year flood; for a low hazard potential CCR surface impoundment, the 100-year flood; and for an incised CCR surface impoundment, the 25-year flood.

(b) Discharge from the CCR unit must be handled in accordance with the surface water requirements under §257.3-3.

1.2 §257.82(c) – Inflow Design Flood Control System Plan

Excerpts from §257.82(c), regarding the inflow design flood control system plan requirements for CCR surface impoundments completed by Gredell Engineering, are provided for reference below.

(c)(1) The owner or operator must prepare initial and periodic inflow design flood control system plans for the CCR unit according the timeframes specified in paragraphs (c)(3) and (4) of this section. These plans must document how the inflow design flood control system has been designed and constructed to meet the requirements of this section. Each plan must be supported by appropriate engineering calculations. The owner or operator of the CCR unit has completed the inflow design flood control system plan when the plan has been placed in the facility's operating record as required by §257.105(g)(4).

(c)(5) The owner or operator must obtain a certification from a qualified professional engineer stating that the initial and periodic inflow design flood control system plan meets the requirements of this section.

1.3 §257.3-3 – Surface Water

Excerpts from §257.3-3, which is referenced in §257.82(b), are provided for reference below.

(a) For purposes of section 4004(a) of the Act, a facility shall not cause a discharge of pollutants into waters of the United States that is in violation of the requirements of the National Pollutant Discharge Elimination System (NPDES) under section 402 of the Clean Water Act, as amended.

(c) A facility or practice shall not cause non-point source pollution of waters of the United States that violates applicable legal requirements implementing an area wide or Statewide water quality management plan that has been approved by the Administrator under section 208 of the Clean Water Act, as amended.

2.0 POND DESCRIPTIONS

SPS is located east of the City of Sikeston, south of West Wakefield Avenue, and west of Route Bb in Scott County, Missouri. The Fly Ash Pond at SPS resides to the northeast of SPS, and directly east of SPS's coal pile and north of the Bottom Ash Pond. The Fly Ash Pond occupies approximately 30 acres with a maximum and consistent berm elevation of 322 feet. Based on an aerial survey conducted by Surdex Corporation on May 6, 2016, the Fly Ash Pond has an approximate remaining capacity of 31.2 acre-feet (ac-ft) (1,359,000 cubic feet [ft³]).

SPS and the Fly Ash Pond are located at a transition between agricultural and urban areas. The Fly Ash Pond is surrounded by agricultural, commercial, and residential areas. Residential areas are located approximately 350 feet north of the Fly Ash Pond. Commercial areas are located approximately 1,700 feet east of the Fly Ash Pond. The remaining area around the Fly Ash Pond is agricultural land. See Appendix A, Figure 1 – Aerial View for a depiction of the Fly Ash Pond.

2.1 Fly Ash Pond Influent and Discharge Systems

SPS discharges no influent into the Fly Ash Pond. The only influent is from precipitation within the limits of the pond. Discharge from the Fly Ash Pond is through a 24-inch corrugated metal pipe in the northwest corner of the pond with an invert elevation of 316.75 feet. The 24-inch pipe discharges Fly Ash Pond effluent into the Process Wastewater Pond. The discharge pipe inlet and outlet invert elevations are 316.75 feet and 307.00 feet respectively. The discharge pipe is about 916 feet long and the slope of the pipe varies. However, over 830 feet of the pipe has an approximate slope of 0.1 percent (%) and was modeled accordingly. Average daily and monthly maximum flow rates from the Fly Ash Pond are shown as influents into the Process Waste Pond in Table 1 – Wastewater Sources.

The existing Fly Ash Pond outlet structure is constructed with a 24-inch steel outlet pipe that drains into the ditch on the north side of the site and a 24-inch corrugated metal pipe that drains into the Process Wastewater Pond. A hand-operated valve, which is located at the Fly Ash Pond's outlet structure near the northwest berm, is used to control the discharge from the Fly Ash Pond. Each pipe is controlled by a gate valve and the steel pipe remains closed. The discharge structure is identified in Appendix A, Figure 3 – F.A.P & Process Waste Pond Hydraulic Structures. Schematic details of the Fly Ash Pond outlet structure are provided in Appendix A, Figure 4 – Outlet Structure Details.

2.2 Bottom Ash Pond Influent and Discharge Systems

SPS discharges influent into the Bottom Ash Pond through three influent pipes located in the northeast corner of the Bottom Ash Pond. Influent consists of CCR and non-CCR wastewaters. Non-CCR wastewater sources include plant maintenance, boiler blowdown wastewaters and

sump water from the concrete utility trench used for plant piping out to the Bottom Ash Pond. Non-CCR wastewaters discharge into the northwest corner of the Bottom Ash Pond through a 12-inch carbon fiber pipe and a 4-inch PVC pipe. Bottom ash handling wastewater is the only CCR wastewater influent into the Bottom Ash Pond. Bottom ash handling wastewater discharges into the northwest corner of the Bottom Ash Pond through an estimated 10-inch ductile iron pipe. Average daily and monthly maximum flow rates for each wastewater source are shown in Table 1 – Wastewater Sources.

Discharge from the Bottom Ash Pond is through a concrete structure with dimensions of 6 feet wide, 11 feet long, and 8.5 feet deep with a top elevation of 322.53 feet. The structure outlet contains a single, 10-inch carbon fiber pipe which discharges Bottom Ash Pond effluent into the Process Waste Pond. The discharge pipe inlet and outlet invert elevations are 314.53 feet and 304.97 feet respectively. A hand-operated valve, which is located near the toe of the Bottom Ash Pond's north berm, is used to control the discharge from the Bottom Ash Pond. The distance from the discharge structure to the control valve is approximately 80 feet and the slope of the discharge pipe is approximately 10.3%. From the control valve, the discharge pipe is routed to the Process Waste Pond over a distance of approximately 1,820 feet with a slope of approximately 0.07%. Average daily and monthly maximum flow rates from the Bottom Ash Pond are shown as influents into the Process Waste Pond in Table 1 – Wastewater Sources.

The existing Bottom Ash Pond overflow structure is constructed with a concrete inlet that has a 30-inch iron discharge pipe through the berm separating the Bottom Ash Pond from the inactive Fly Ash Pond. The discharge of the overflow structure is into the inactive Fly Ash Pond. The overflow structure is inoperable due to excess CCR deposits in the inactive Fly Ash Pond obstructing the discharge end of the 30-inch pipe. Influent and discharge structures are identified in Appendix A, Figure 2 – Bottom Ash Pond Hydraulic Structures. Schematic details of the Bottom Ash Pond outlet structure are provided in Appendix A, Figure 4 – Outlet Structure Details.

2.3 Settling Pond Influent and Discharge Systems

SPS discharges influent into the Settling Pond through an inlet located in the southeast corner of the Settling Pond. Influent consists of non-CCR wastewaters. Non-CCR wastewater sources include coal pile runoff and coal handling wash down wastewaters. Runoff from approximately 15.1 acres of the coal/limestone storage area is estimated to discharge into the Settling Pond. Non-CCR wastewaters discharge into the Settling Pond through a structure series of four arched influent pipes. Average daily and monthly maximum flow rates for each wastewater source are shown in Table 1 – Wastewater Sources.

Discharge from the Settling Pond is through a principal spillway consisting of a 36-inch diameter corrugated metal. The Settling Pond effluent discharges into the Process Waste Pond. The principle discharge pipe inlet and outlet invert elevations are 304.8 feet and 304.55 feet respectively. The slope and length of the discharge pipe are approximately 0.6% and 41 feet.

Average daily and monthly maximum flow rates from the Settling Pond are shown as influents into the Process Waste Pond in Table 1 – Wastewater Sources.

The existing Settling Pond emergency spillway is constructed as a 37-foot long concrete broad crested weir. The width of the weir is approximately 30 feet long. The inlet and outlet invert elevations are 306.40 feet and 306.32 feet respectively. The emergency spillway discharges into the Process Waste Pond. Influent and discharge structures are identified in Appendix A, Figure 3 – Process Waste Pond Hydraulic Structures.

2.4 Process Waste Pond Influent and Discharge Systems

SPS discharges influent into the Process Waste Pond through five influent pipes located along the southern bank and in the northeast corner of the Process Waste Pond. Influent consists of non-CCR wastewaters. Non-CCR wastewaters sources include coal/limestone pile runoff, demineralizer water, Fly Ash Pond effluent, Bottom Ash Pond effluent, and Settling Pond Effluent. Bottom Ash Pond, Fly Ash Pond, and Settling Pond effluents are not CCR wastewaters because the wastewaters include only de minimus quantities of CCR. The Process Waste Pond is approximately 9.6 acres.

Non-CCR wastewaters discharge into the Process Waste Pond through a 10-inch carbon fiber pipe (Bottom Ash Pond effluent), a 24-inch CMP (Fly Ash Pond effluent) and a 3-inch carbon fiber pipe (demineralizer wastewater). Invert elevations of the 10-inch and 3-inch carbon pipe influents are 304.97 feet, 307.00 feet, and 305.01 feet respectively.

Runoff from approximately 23.8 acres of the coal pile storage area discharges into the Process Waste Pond through a 24-inch corrugated metal pipe. The 24-inch corrugated metal pipe inlet and outlet invert elevations are 309.06 feet and 306.65 feet respectively. The minimum slope and length were determined to be approximately at 3.2 % and 75 feet.

Discharge from the Process Waste Pond is through a concrete stop log structure with dimensions of 5 feet wide, 18 feet long, and 8 feet deep. The concrete structure contains a 3 foot wide rectangular weir at an approximate elevation of 303.8 feet. The pond is discharged through a 24-inch corrugated metal pipe which discharges Process Waste Pond effluent to Richland Drainage Ditch #4 through Outfall 003 (Missouri State Operating Permit MO-0095575). The discharge pipe inlet and outlet invert elevations were estimated to be approximately 301.4 feet and 300.3 feet respectively. The discharge pipe was assumed to have a minimum slope of 0.5% and a length of approximately 230 feet. Average daily and monthly maximum flow rates from the Process Waste Pond are shown in Table 1 – Wastewater Sources. There is no emergency spillway for the Process Waste Pond. All influent and discharge structures are identified in Appendix A, Figure 3 – Process Waste Pond Hydraulic Structures. Schematic details of the Process Waste Pond outlet structure are provided in Appendix A, Figure 4 – Outlet Structure Details.

Table 1: Wastewater Sources

| Discharging Water Body / Process | Receiving Water Body | Average Daily Flowrate (MGD) | Maximum Daily Flowrate (MGD) |
|---|-----------------------------|-------------------------------------|-------------------------------------|
| Oil Separator | Bottom Ash Pond | 0.06 | 0.06 |
| Boiler Blowdown Tank | Bottom Ash Pond | 0.05 | 0.07 |
| Precipitation² | Bottom Ash Pond | 0.08 | 0.85 |
| Coal Handling Washdown | Settling Pond | 0.05 | 0.10 |
| Precipitation² | Settling Pond | 0.04 | 0.42 |
| Bottom Ash Pond | Process Waste Pond | 1.22 | 2.13 |
| Demineralizer | Process Waste Pond | 0.02 | 0.02 |
| Settling Pond | Process Waste Pond | 0.09 | 0.52 |
| Precipitation² | Process Waste Pond | 0.01 | 0.16 |
| Process Waste Pond | Richland Drainage Ditch #4 | 1.38 | 3.27 |

1. Wastewater Source flowrates were taken from the Process Flow Diagram dated 7-15-2013 that was prepared and provided by SPS.

2. Precipitation values provided by SPS were not used in the Hydraflow model. Precipitation values were calculated by Hydraflow utilizing the inflow design flood of a 100-yr flood event.

3.0 INFLOW DESIGN FLOOD

§257.82 requires owners and operators of CCR surface impoundments to have hydrologic and hydraulic systems designed to adequately manage the flow from the peak discharge of the inflow design flood into and out of the CCR surface impoundment. The inflow design flood is determined by the hazard potential classification for the CCR surface impoundment. As previously stated, §257.82(a)(3) defines the inflow design flood for each hazard potential classification. The potential inflow design flood for CCR surface impoundments are as follows:

- High Hazard Potential – probably maximum flood
- Significant Hazard Potential – 1,000-year flood
- Low Hazard Potential – 100 year flood

3.1 Fly Ash Pond Hazard Potential Classification

The hazard potential classification for the Fly Ash Pond was determined by modeling a worst-case scenario breach of the Fly Ash Pond Berms and its resulting flood waters impact on the surrounding land. A worst-case scenario breach of the Fly Ash Pond berm at SPS was modeled using HydroCAD. The flooded areas from the modeled breach include agricultural (owned by the City of Sikeston).

Flood waters from a breach in the Fly Ash Pond berm under the worst-case scenario conditions will be contained to property owned by the City of Sikeston and the residential area to the southeast of SPS. Additionally, environmental damage, economic loss, disruption of lifeline facilities, or other impact concerns are not expected from a breach in the fly Ash Pond berm. There is no probable loss of human life due to the flood waters from the breach in the Fly Ash Pond berm. Therefore, the Fly Ash Pond at SPS was classified as: Low Hazard Potential Classification.

3.2 Fly Ash Pond Inflow Design Flood

As stated above, §257.82(a)(3) requires the inflow design flood for CCR surface impoundments with low hazard potential classifications to be the 100-year flood. The 100-year flood is the volume of runoff generated by the 100-year rainfall event for a given location. The duration of the 100-year event was taken to be 24 hours. The 24 hour duration was used as it generated the maximum runoff volume. The 100-year, 24-hour rainfall event was modeled to determine if the existing hydrologic and hydraulic capacity of the Fly Ash Pond and other hydraulic structures impacted by the discharge from the Fly Ash Pond is adequate. From the National Oceanic and Atmospheric Administration (NOAA) Atlas 14, Volume 8, Version 2, the 100-year, 24-hour depth of rainfall for Sikeston, Missouri is 8.44 inches.

4.0 INFLOW DESIGN FLOOD CONTROL SYSTEM

As previously stated above, §257.82(a)(1) and (2) pertaining to CCR surface impoundments states owners or operators of CCR surface impoundments must design, construct, operate, and maintain the inflow design flood control system to adequately manage flow into the CCR surface impoundment during and following the peak discharge of the inflow design flood, as well as adequately manage the flow from the CCR unit to collect and control the peak discharge resulting from the inflow design flood. Therefore, the inflow design flood control system for the Fly Ash Pond includes the following hydraulic structures which were modeled using Hydraflow.

- Fly Ash Pond
- Bottom Ash Pond
- Settling Pond
- Process Waste Pond

4.1 Fly Ash Pond Inflow and Outflow

The Fly Ash Pond was modeled using Hydraflow with one input, the 100-year storm event. The watershed for the Fly Ash Pond is solely the area within the berms of the Fly Ash Pond. The Fly Ash Pond berms elevations are above the surrounding topography and therefore, do not receive additional stormwater runoff.

The peak discharge from the 100-year flood was determined to be 146 cubic feet per second (CFS). The average daily runoff rate into the Fly Ash Pond was determined to be approximately 5.4 million gallons per day (MGD) with a total influent volume of approximately 715,373 ft³ (5.4 MG). The initial water elevation in the Fly Ash Pond was assumed to be 316.7 feet, the average water elevation as recorded in the weekly inspection reports for the Fly Ash Pond. The maximum water elevation in the Fly Ash Pond was determined to be 320.1 feet, 1.9 feet below the top of the Fly Ash Pond berms (elevation 322 feet). The remaining capacity of the Fly Ash Pond with 1.9 feet of vertical storage is approximately 638,000 ft³. The peak discharge from the Fly Ash Pond during the 100-year inflow design flood was determined to be 6.43 CFS. The average daily discharge rate from the Fly Ash Pond was determined to be approximately 329,000 ft³/day (2.5 MGD). Therefore, the Fly Ash Pond hydrologic and hydraulic capacity can adequately manage flow during and following the peak discharge from the inflow design flood as required by §257.82(a)(1). See Appendix B, Hydraflow Report - 100-year Design Flood for a detailed report of the hydrologic and hydraulic model.

4.2 Bottom Ash Pond Inflow and Outflow

The Bottom Ash Pond was modeled using Hydraflow with two inputs, the 100-year storm event and Sikeston Power Station process wastewaters. Sikeston Power Station process wastewaters

include Bottom Ash Handling and Maintenance and Operations. The maximum daily flow rates from Table 1 were used to develop a conservative model. It should be noted that due to the limitations of the modeling software, process wastewater flows were modeled using artificial drainage areas and runoff coefficients to yield the desired maximum daily flowrates reported in Table 1. The watershed for the Bottom Ash Pond is solely the area within the berms of the Bottom Ash Pond. The Bottom Ash Pond berms elevations are above the surrounding topography and therefore, do not receive additional stormwater runoff.

The peak discharge from the combined process wastewaters and the 100-year flood was determined to be 681.3 cubic feet per second (CFS). The average daily discharge rate into the Bottom Ash Pond was determined to be approximately 14.2 million gallons per day (MGD) with a total influent volume of approximately 1,903,500 ft³ (14.2 MG). The initial water elevation in the Bottom Ash Pond was assumed to be 318.5 feet, the average water elevation as recorded in the weekly inspection reports for the Bottom Ash Pond. The maximum water elevation in the Bottom Ash Pond from the combined influents was determined to be 319.9 feet, 2.1 feet below the top of the Bottom Ash Pond berms (elevation 322 feet). The remaining capacity of the Bottom Ash Pond with 2.1 feet of vertical storage is approximately 4,379,500 ft³. Due to the throttling of the 10-inch discharge pipe, the discharge from the Bottom Ash Pond during the 100-year inflow design flood was determined to be 1.78 CFS. The average daily discharge rate was determined to be approximately 153,800 ft³/day (1.2 MGD). Therefore, the Bottom Ash Pond hydrologic and hydraulic capacity can adequately manage flow during and following the peak discharge from the inflow design flood as required by §257.82(a)(1). See Appendix B, Hydraflow Report - 100-year Design Flood for a detailed report of the hydrologic and hydraulic model.

4.3 Settling Pond Inflow and Outflow

The Settling Pond was modeled using Hydraflow with three inputs, the 100-year storm event, Settling Pond discharge, coal pile runoff from the 100-year storm event, and the runoff from the Settling Pond. The maximum daily flow rates from Table 1 were used to develop a conservative model. As previously stated, process wastewater flows were modeled using artificial drainage areas and runoff coefficients to yield the desired maximum daily flowrates reported in Table 1. The watershed for the Settling Pond includes the Settling Pond itself and the coal yard directly east of the Settling Pond. The Settling Pond and the coal pile storage area are surrounded by berms with elevations greater than the surrounding topography, and therefore do not receive any additional stormwater runoff.

The peak discharge from the combined inputs to the Settling Pond was determined to be 94.8 CFS. The average daily discharge rate into the Settling Pond was determined to be approximately 2.6 MGD with a total influent volume of approximately 341,800 ft³ (2.6 MG). The initial water elevation in the Settling Pond was assumed to be 304.6 feet, the normal operational elevation of the Settling Pond. The maximum water elevation in the Settling Pond from the resulting from the combined influents was determined to be 306.5 feet, 2.5 feet below the top of the Settling Pond

berms (elevation 309 feet). The remaining capacity of the Settling Pond with an approximate area of 2.4 acres and 2.5 feet of storage is approximately 248,500 ft³. The peak discharge from the Settling Pond during the 100-year inflow design flood was determined to be 16.7 CFS. The average daily discharge from the Settling Pond was determined to be approximately 314,100 ft³/day (2.3 MGD). Therefore, the Settling Pond hydrologic and hydraulic capacity can adequately manage flow during and following the peak discharge from the inflow design flood as required by §257.82(a)(1). See Appendix B, Hydraflow Report - 100-year Design Flood for a detailed report of the hydrologic and hydraulic model.

4.4 Process Waste Pond Inflow and Outflow

The Process Waste Pond was modeled using Hydraflow with six inputs, the 100-year storm event, Settling Pond discharge, Bottom Ash Pond discharge, Fly Ash Pond discharge, coal pile runoff from the 100-year storm event, and demineralizer wastewater flows. The maximum daily flow rates from Table 1 were used to develop a conservative model. As previously stated, process wastewater flows were modeled using artificial drainage areas and runoff coefficients to yield the desired maximum daily flowrates reported in Table 1. The watershed for the Process Waste Pond includes the Process Waste Pond itself and the coal yard directly east of the Process Waste Pond. The Process Waste Pond and the coal pile storage area are surrounded by berms with elevations greater than the surrounding topography, and therefore do not receive any additional stormwater runoff.

The peak discharge from the combined inputs to the Process Waste Pond was determined to be 207.2 CFS. The average daily discharge rate into the Process Waste Pond was determined to be approximately 11.8 MGD with a total influent volume of approximately 1,666,200 ft³ (12.4 MG). The initial water elevation in the Process Waste Pond was assumed to be 303.8 feet, the normal operational elevation of the Process Waste Pond. The maximum water elevation in the Process Waste Pond resulting from the combined influents was determined to be approximately 305.5 feet, or 3.5 feet below the top of the Process Waste Pond berms (approximate elevation 309 feet). The remaining capacity of the Process Waste Pond with approximately 3.5 feet of vertical storage is approximately 1,457,900 ft³ (10.9 MGD). The peak discharge from the Process Waste Pond during the 100-year inflow design flood was determined to be 18.3 CFS. The average daily discharge from the Process Waste Pond was determined to be approximately 740,500 ft³/day (5.5 MGD). Therefore, the Process Waste Pond hydrologic and hydraulic capacity can adequately manage flow during and following the peak discharge from the inflow design flood as required by §257.82(a)(1). See Appendix B, Hydraflow Report - 100-year Design Flood for a detailed report of the hydrologic and hydraulic model.

4.5 Clean Water Act Surface Water Requirements

40 CFR 257.82 requires owners and operators of CCR surface impoundments to manage discharge during and following the inflow design flood in accordance with the surface water

requirements of §257.3-3. As previously stated, §257.3-3 requires discharges from CCR surface impoundments into waters of the United States to be conducted in manner which does not violate NPDES requirements and which does not cause non-point source pollution of waters of the United States. Since the majority of the discharge is a direct result from the volume of stormwater runoff generated during a 100-year event, it is presumed that the amount of constituents present in the effluent will be in compliance with SPS's operating permit. SPS will continue monitoring, sampling, and record keeping operations as required by the operating permit during a 100-year event to maintain compliance with the operating permit and thereby satisfy the requirements of §257.3-3.

It is noted that the Process Waste Pond discharges through Outfall #003, which is regulated by Missouri State Operating Permit MO-0095575. Under the regulating statutes, Chapter 644.076(4) RS MO states that,

“The liabilities which shall be imposed pursuant to any provision of sections [644.006](#) to [644.141](#) upon persons violating the provisions of sections [644.006](#) to [644.141](#) or any standard, rule, limitation, or regulation adopted pursuant thereto shall not be imposed due to any violation caused by an act of God, war, strike, riot, or other catastrophe.”

The 100-year flood is viewed as a common storm event. Even though it was determined that the berms would not be overtopped during the event, the provisions of 644.076(4) are presumed to be applicable.

5.0 RECOMMENDATIONS

The presumed normal operating conditions are: the Fly Ash Pond operating at an elevation of 316.5 feet; the Bottom Ash Pond operating at an elevation of 318.5 feet; the Settling Pond operating at an elevation of 304.6 feet; and the Process Waste Pond Operating at 303.8 feet. Under these conditions, it was determined that the CCR impoundment and non-CCR impoundments affected by its discharge, have sufficient hydrologic and hydraulic capacity to adequately manage flow during and following the peak discharge from the inflow design flood as required by §257.82(a)(1).

Furthermore, it was also determined that if the valve on the Fly Ash Pond was closed during the 100-year flood event, the Fly Ash Pond has capacity to store the entire 100-year flood event. With the valve completely closed during this event, the Fly Ash Pond would not discharge flows and the maximum water surface elevation was determined to be approximately 320.6 feet, leaving approximately 1.4 feet of freeboard in the pond.

It is recommended that before or during an anticipated heavy rainfall event (up to a 100-year event), the stop logs in the Process Waste Pond be set at an elevation below 306.0 feet to maintain a minimum freeboard of 1+/- feet in the Process Waste Pond.

6.0 PERIODIC PLAN PROCEDURES

As per §257.82(c)(4), the owner or operator must prepare periodic inflow design flood control system plans every five years. The date of completing the initial plan is the basis for establishing the deadline to complete the first periodic plan. The deadline for completing a subsequent plan is based on the date for completing the previous plan. The first periodic plan must be completed on or prior to April 17 in the year 2023, which corresponds to the completion of the initial inflow design flood control plan on April 17, 2018.

7.0 PLAN AMENDMENTS

This Inflow Design Flood Control System Plan will be amended, as per §257.82(c)(2), whenever there is a change in conditions that would substantially affect the written plan in effect, such as modifications to hydraulic structures of the Fly Ash Pond, additional influents or additional effluents.

8.0 MISCELLANEOUS REQUIREMENTS

Section 257.82(d) states that SBMU must comply with:

- The recordkeeping requirements specified in 257.105(g);
- The notification requirements specified in 257.106(g); and,
- The Internet requirements specified in 257.107(g).

APPENDIX A

Figures



SCALE: 1" = 1500'
 0 750 1500

**INFLOW DESIGN FLOOD
 CONTROL SYSTEM PLAN
 FLY ASH POND
 SIKESTON POWER STATION**

GREDELL Engineering Resources, Inc.

ENVIRONMENTAL ENGINEERING LAND - AIR - WATER


1505 East High Street
 Jefferson City, Missouri

Telephone: (573) 659-9078
 Facsimile: (573) 659-9079

MO CORP. ENGINEERING LICENSE NO. E-2001001669-D

FIGURE 1 - AERIAL VIEW

| DATE | SCALE | PROJECT NAME | REVISION |
|-------------|----------------|---|-------------------|
| 4/2018 | AS NOTED | SIKESTON | |
| DRAWN CP | APPROVED JB | FILE NAME INFLOW DESIGN FLOOD CNTRL SYS PLAN | SHEET # 1 OF 1 |



**INFLOW DESIGN FLOOD CONTROL SYSTEM PLAN
FLY ASH POND
SIKESTON POWER STATION**

GREDELL Engineering Resources, Inc.

ENVIRONMENTAL ENGINEERING LAND - AIR - WATER



1505 East High Street
Jefferson City, Missouri

Telephone: (573) 659-9078
Facsimile: (573) 659-9079

MO CORP. ENGINEERING LICENSE NO. E-2001001669-D

**FIGURE 2 - BOTTOM ASH POND
HYDRAULIC STRUCTURES**

| DATE | SCALE | PROJECT NAME | REVISION |
|-------------|----------------|---|-------------------|
| 4/2018 | AS NOTED | SIKESTON | |
| DRAWN CP | APPROVED JB | FILE NAME INFLOW DESIGN FLOOD CNTRL SYS PLAN | SHEET # 1 OF 1 |



**INFLOW DESIGN FLOOD
CONTROL SYSTEM PLAN
FLY ASH POND
SIKESTON POWER STATION**

GREDELL Engineering Resources, Inc.

ENVIRONMENTAL ENGINEERING LAND - AIR - WATER


1505 East High Street
Jefferson City, Missouri

Telephone: (573) 659-9078
Facsimile: (573) 659-9079


MO CORP. ENGINEERING LICENSE NO. E-2001001669-D

**FIGURE 3 - FAP & PROCESS WASTE
POND HYDRAULIC STRUCTURES**

| DATE | SCALE | PROJECT NAME | REVISION |
|-------------|----------------|---|-------------------|
| 4/2018 | AS NOTED | SIKESTON | |
| DRAWN CP | APPROVED JB | FILE NAME INFLOW DESIGN FLOOD CNTRL SYS PLAN | SHEET # 1 OF 1 |




PLAN VIEW




SECTION A-A

**FLY ASH POND
OUTLET STRUCTURE**
SCALE: N.T.S.



PLAN VIEW



SECTION A-A

**PROCESS WASTEWATER POND
OUTLET STRUCTURE**
SCALE: N.T.S.

NOTE:
NO CONSTRUCTION PLANS WERE AVAILABLE FOR THE PROCESS WASTEWATER POND OUTLET STRUCTURE. SCHEMATIC DRAWINGS BASED ON LIMITED SITE OBSERVATIONS & ENGINEERING JUDGEMENT AS MOST OF THE OUTLET WAS SUBMERGED AT THE TIME OF THE SITE VISIT.

**INFLOW DESIGN FLOOD
CONTROL SYSTEM PLAN
FLY ASH POND
SIKESTON POWER STATION**

GREDELL Engineering Resources, Inc.

ENVIRONMENTAL ENGINEERING LAND - AIR - WATER

1505 East High Street
Jefferson City, Missouri

Telephone: (573) 659-9078
Facsimile: (573) 659-9079

MO CORP. ENGINEERING LICENSE NO. E-2001001669-D

FIGURE 4 - OUTLET STRUCTURE DETAILS


| DATE | SCALE | PROJECT NAME | REVISION |
|-------------|----------------|---|-------------------|
| 4/2018 | AS NOTED | SIKESTON | |
| DRAWN CP | APPROVED CP | FILE NAME INFLOW DESIGN FLOOD CNTRL SYS PLAN | SHEET # 1 OF 1 |

APPENDIX B

Hydraflow Report – 100 Year Design Flood

Watershed Model Schematic

Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2016 by Autodesk, Inc. v11



Hydrograph Summary Report

Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2016 by Autodesk, Inc. v11

| Hyd. No. | Hydrograph type (origin) | Peak flow (cfs) | Time interval (min) | Time to Peak (min) | Hyd. volume (cuft) | Inflow hyd(s) | Maximum elevation (ft) | Total strge used (cuft) | Hydrograph Description | |
|--------------------------------|--------------------------|-----------------|---------------------|--------------------|-------------------------|--------------------|------------------------|-------------------------|---------------------------------------|--|
| 1 | Rational | 4.606 | 1 | 720 | 198,973 | ----- | ----- | ----- | Ash Handling, Oil Sep., and Boiler Ta | |
| 2 | SCS Runoff | 676.72 | 1 | 717 | 1,704,528 | ----- | ----- | ----- | Bottom Ash Pond Runoff | |
| 3 | Combine | 681.30 | 1 | 717 | 1,903,500 | 1, 2 | ----- | ----- | Combined Bottom Ash Flows | |
| 4 | Reservoir | 1.782 | 1 | 1543 | 268,123 | 3 | 319.91 | 8,946,062 | Bottom Ash Pond | |
| 5 | SCS Runoff | 121.36 | 1 | 717 | 301,487 | ----- | ----- | ----- | Process Pond Runoff | |
| 6 | Rational | 0.062 | 1 | 720 | 2,686 | ----- | ----- | ----- | Demineralizer Inflow | |
| 7 | SCS Runoff | 80.88 | 1 | 725 | 252,547 | ----- | ----- | ----- | Coal Pile Runoff Settling Pond | |
| 8 | SCS Runoff | 116.21 | 1 | 727 | 394,501 | ----- | ----- | ----- | Coal Pile Runoff | |
| 9 | Rational | 0.311 | 1 | 720 | 13,428 | ----- | ----- | ----- | Coal Handling Washdown Inflow | |
| 10 | SCS Runoff | 30.10 | 1 | 717 | 75,827 | ----- | ----- | ----- | Settling Pond Runoff | |
| 11 | Combine | 94.75 | 1 | 721 | 341,802 | 7, 9, 10 | ----- | ----- | Settling Pond Inflow | |
| 12 | Reservoir | 16.68 | 1 | 749 | 314,084 | 11 | 306.52 | 791,144 | Settling Pond | |
| 13 | SCS Runoff | 146.18 | 1 | 737 | 715,373 | ----- | ----- | ----- | Fly Ash Pond Runoff | |
| 14 | Reservoir | 6.429 | 1 | 970 | 657,837 | 13 | 320.14 | 658,119 | Fly Ash Pond | |
| 15 | Combine | 207.24 | 1 | 718 | 1,938,719 | 4, 5, 6, 8, 12, 14 | ----- | ----- | Process Pond Inflow | |
| 16 | Reservoir | 18.33 | 1 | 1065 | 1,666,155 | 15 | 305.46 | 3,206,778 | Process Waste Pond | |
| Inflow Flood Design 4-9-18.gpw | | | | | Return Period: 100 Year | | | Monday, 04 / 9 / 2018 | | |

Hydrograph Report


Hyd. No. 1

Ash Handling, Oil Sep., and Boiler Tank Inflow

| | | | |
|-----------------|---------------|-------------------|----------------|
| Hydrograph type | = Rational | Peak discharge | = 4.606 cfs |
| Storm frequency | = 100 yrs | Time to peak | = 12.00 hrs |
| Time interval | = 1 min | Hyd. volume | = 198,973 cuft |
| Drainage area | = 8.150 ac | Runoff coeff. | = 0.99 |
| Intensity | = 0.571 in/hr | Tc by User | = 720.00 min |
| IDF Curve | = IDF.IDF | Asc/Rec limb fact | = 1/1 |

Ash Handling, Oil Sep., and Boiler Tank Inflow

Hyd. No. 1 -- 100 Year




Hydrograph Report

Hyd. No. 2

Bottom Ash Pond Runoff

| | | | |
|-----------------|--------------|--------------------|------------------|
| Hydrograph type | = SCS Runoff | Peak discharge | = 676.72 cfs |
| Storm frequency | = 100 yrs | Time to peak | = 11.95 hrs |
| Time interval | = 1 min | Hyd. volume | = 1,704,528 cuft |
| Drainage area | = 53.950 ac | Curve number | = 100 |
| Basin Slope | = 0.0 % | Hydraulic length | = 0 ft |
| Tc method | = User | Time of conc. (Tc) | = 5.00 min |
| Total precip. | = 8.44 in | Distribution | = Type II |
| Storm duration | = 24 hrs | Shape factor | = 484 |



Hydrograph Report


Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2016 by Autodesk, Inc. v11

Monday, 04 / 9 / 2018

Hyd. No. 3

Combined Bottom Ash Flows

| | | | |
|-----------------|-----------|----------------------|------------------|
| Hydrograph type | = Combine | Peak discharge | = 681.30 cfs |
| Storm frequency | = 100 yrs | Time to peak | = 11.95 hrs |
| Time interval | = 1 min | Hyd. volume | = 1,903,500 cuft |
| Inflow hyds. | = 1, 2 | Contrib. drain. area | = 62.100 ac |



Hydrograph Report

Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2016 by Autodesk, Inc. v11


Monday, 04 / 9 / 2018

Hyd. No. 4

Bottom Ash Pond

| | | | |
|-----------------|--------------------------------|----------------|------------------|
| Hydrograph type | = Reservoir | Peak discharge | = 1.782 cfs |
| Storm frequency | = 100 yrs | Time to peak | = 25.72 hrs |
| Time interval | = 1 min | Hyd. volume | = 268,123 cuft |
| Inflow hyd. No. | = 3 - Combined Bottom Ash Flow | Max. Elevation | = 319.91 ft |
| Reservoir name | = Bottom Ash Pond | Max. Storage | = 8,946,062 cuft |

Storage Indication method used. Wet pond routing start elevation = 318.50 ft.



Pond No. 1 - Bottom Ash Pond

Pond Data

Contours -User-defined contour areas. Average end area method used for volume calculation. Beginning Elevation = 305.00 ft

Stage / Storage Table

| Stage (ft) | Elevation (ft) | Contour area (sqft) | Incr. Storage (cuft) | Total storage (cuft) |
|------------|----------------|---------------------|----------------------|----------------------|
| 0.00 | 305.00 | 00 | 0 | 0 |
| 1.00 | 306.00 | 500,538 | 250,269 | 250,269 |
| 2.00 | 307.00 | 500,538 | 500,538 | 750,807 |
| 3.00 | 308.00 | 500,538 | 500,538 | 1,251,345 |
| 4.00 | 309.00 | 500,538 | 500,538 | 1,751,883 |
| 5.00 | 310.00 | 500,538 | 500,538 | 2,252,421 |
| 6.00 | 311.00 | 500,538 | 500,538 | 2,752,959 |
| 7.00 | 312.00 | 500,538 | 500,538 | 3,253,497 |
| 8.00 | 313.00 | 500,538 | 500,538 | 3,754,035 |
| 9.00 | 314.00 | 500,538 | 500,538 | 4,254,573 |
| 10.00 | 315.00 | 500,538 | 500,538 | 4,755,111 |
| 11.00 | 316.00 | 530,032 | 515,285 | 5,270,396 |
| 12.00 | 317.00 | 657,511 | 593,772 | 5,864,168 |
| 13.00 | 318.00 | 897,070 | 777,290 | 6,641,458 |
| 14.00 | 319.00 | 1,168,041 | 1,032,556 | 7,674,014 |
| 15.00 | 320.00 | 1,635,975 | 1,402,008 | 9,076,022 |
| 16.00 | 321.00 | 2,256,627 | 1,946,298 | 11,022,320 |
| 17.00 | 322.00 | 2,349,932 | 2,303,280 | 13,325,600 |


Culvert / Orifice Structures

| | [A] | [B] | [C] | [PrfRsr] |
|-----------------|-----------|------|------|----------|
| Rise (in) | = 10.00 | 0.00 | 0.00 | 0.00 |
| Span (in) | = 10.00 | 0.00 | 0.00 | 0.00 |
| No. Barrels | = 1 | 0 | 0 | 0 |
| Invert El. (ft) | = 314.53 | 0.00 | 0.00 | 0.00 |
| Length (ft) | = 1900.00 | 0.00 | 0.00 | 0.00 |
| Slope (%) | = 0.50 | 0.00 | 0.00 | n/a |
| N-Value | = .013 | .013 | .013 | n/a |
| Orifice Coeff. | = 0.60 | 0.60 | 0.60 | 0.60 |
| Multi-Stage | = n/a | No | No | No |

Weir Structures

| | [A] | [B] | [C] | [D] |
|----------------|----------------------|------|------|------|
| Crest Len (ft) | = 4.00 | 0.00 | 0.00 | 0.00 |
| Crest El. (ft) | = 318.50 | 0.00 | 0.00 | 0.00 |
| Weir Coeff. | = 3.33 | 3.33 | 3.33 | 3.33 |
| Weir Type | = Rect | --- | --- | --- |
| Multi-Stage | = Yes | No | No | No |
| Exfil.(in/hr) | = 0.000 (by Contour) | | | |
| TW Elev. (ft) | = 307.00 | | | |

Note: Culvert/Orifice outflows are analyzed under inlet (ic) and outlet (oc) control. Weir risers checked for orifice conditions (ic) and submergence (s).



Hydrograph Report


Hyd. No. 5

Process Pond Runoff

| | | | |
|-----------------|--------------|--------------------|----------------|
| Hydrograph type | = SCS Runoff | Peak discharge | = 121.36 cfs |
| Storm frequency | = 100 yrs | Time to peak | = 11.95 hrs |
| Time interval | = 1 min | Hyd. volume | = 301,487 cuft |
| Drainage area | = 9.680 ac | Curve number | = 99 |
| Basin Slope | = 0.0 % | Hydraulic length | = 0 ft |
| Tc method | = User | Time of conc. (Tc) | = 5.00 min |
| Total precip. | = 8.44 in | Distribution | = Type II |
| Storm duration | = 24 hrs | Shape factor | = 484 |

Process Pond Runoff

Hyd. No. 5 -- 100 Year




Hydrograph Report

Hyd. No. 6

Demineralizer Inflow

| | | | |
|-----------------|---------------|-------------------|--------------|
| Hydrograph type | = Rational | Peak discharge | = 0.062 cfs |
| Storm frequency | = 100 yrs | Time to peak | = 12.00 hrs |
| Time interval | = 1 min | Hyd. volume | = 2,686 cuft |
| Drainage area | = 0.110 ac | Runoff coeff. | = 0.99 |
| Intensity | = 0.571 in/hr | Tc by User | = 720.00 min |
| IDF Curve | = IDF.IDF | Asc/Rec limb fact | = 1/1 |



Hydrograph Report

Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2016 by Autodesk, Inc. v11


Monday, 04 / 9 / 2018

Hyd. No. 7

Coal Pile Runoff Settling Pond

| | | | |
|-----------------|--------------|--------------------|----------------|
| Hydrograph type | = SCS Runoff | Peak discharge | = 80.88 cfs |
| Storm frequency | = 100 yrs | Time to peak | = 12.08 hrs |
| Time interval | = 1 min | Hyd. volume | = 252,547 cuft |
| Drainage area | = 15.100 ac | Curve number | = 68 |
| Basin Slope | = 0.0 % | Hydraulic length | = 0 ft |
| Tc method | = TR55 | Time of conc. (Tc) | = 19.00 min |
| Total precip. | = 8.44 in | Distribution | = Type II |
| Storm duration | = 24 hrs | Shape factor | = 484 |

Coal Pile Runoff Settling Pond



Hydrograph Report


Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2016 by Autodesk, Inc. v11

Monday, 04 / 9 / 2018

Hyd. No. 8

Coal Pile Runoff

| | | | |
|-----------------|--------------|--------------------|----------------|
| Hydrograph type | = SCS Runoff | Peak discharge | = 116.21 cfs |
| Storm frequency | = 100 yrs | Time to peak | = 12.12 hrs |
| Time interval | = 1 min | Hyd. volume | = 394,501 cuft |
| Drainage area | = 23.800 ac | Curve number | = 68 |
| Basin Slope | = 0.0 % | Hydraulic length | = 0 ft |
| Tc method | = TR55 | Time of conc. (Tc) | = 23.00 min |
| Total precip. | = 8.44 in | Distribution | = Type II |
| Storm duration | = 24 hrs | Shape factor | = 484 |



Hydrograph Report

Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2016 by Autodesk, Inc. v11

Monday, 04 / 9 / 2018


Hyd. No. 9

Coal Handling Washdown Inflow

| | | | |
|-----------------|---------------|-------------------|---------------|
| Hydrograph type | = Rational | Peak discharge | = 0.311 cfs |
| Storm frequency | = 100 yrs | Time to peak | = 12.00 hrs |
| Time interval | = 1 min | Hyd. volume | = 13,428 cuft |
| Drainage area | = 0.550 ac | Runoff coeff. | = 0.99 |
| Intensity | = 0.571 in/hr | Tc by User | = 720.00 min |
| IDF Curve | = IDF.IDF | Asc/Rec limb fact | = 1/1 |

Coal Handling Washdown Inflow

Hyd. No. 9 -- 100 Year



Hydrograph Report

Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2016 by Autodesk, Inc. v11

Monday, 04 / 9 / 2018


Hyd. No. 10

Settling Pond Runoff

| | | | |
|-----------------|--------------|--------------------|---------------|
| Hydrograph type | = SCS Runoff | Peak discharge | = 30.10 cfs |
| Storm frequency | = 100 yrs | Time to peak | = 11.95 hrs |
| Time interval | = 1 min | Hyd. volume | = 75,827 cuft |
| Drainage area | = 2.400 ac | Curve number | = 100 |
| Basin Slope | = 0.0 % | Hydraulic length | = 0 ft |
| Tc method | = User | Time of conc. (Tc) | = 5.00 min |
| Total precip. | = 8.44 in | Distribution | = Type II |
| Storm duration | = 24 hrs | Shape factor | = 484 |

Settling Pond Runoff

Hyd. No. 10 -- 100 Year



Hydrograph Report

Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2016 by Autodesk, Inc. v11


Monday, 04 / 9 / 2018

Hyd. No. 11

Settling Pond Inflow

Hydrograph type = Combine
 Storm frequency = 100 yrs
 Time interval = 1 min
 Inflow hyds. = 7, 9, 10

Peak discharge = 94.75 cfs
 Time to peak = 12.02 hrs
 Hyd. volume = 341,802 cuft
 Contrib. drain. area = 18.050 ac



Hydrograph Report

Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2016 by Autodesk, Inc. v11


Monday, 04 / 9 / 2018

Hyd. No. 12

Settling Pond

| | | | |
|-----------------|-----------------------------|----------------|----------------|
| Hydrograph type | = Reservoir | Peak discharge | = 16.68 cfs |
| Storm frequency | = 100 yrs | Time to peak | = 12.48 hrs |
| Time interval | = 1 min | Hyd. volume | = 314,084 cuft |
| Inflow hyd. No. | = 11 - Settling Pond Inflow | Max. Elevation | = 306.52 ft |
| Reservoir name | = Settling Pond | Max. Storage | = 791,144 cuft |

Storage Indication method used. Wet pond routing start elevation = 304.60 ft.



Pond No. 3 - Settling Pond

Pond Data

Contours -User-defined contour areas. Average end area method used for volume calculation. Beginning Elevation = 297.00 ft

Stage / Storage Table

| Stage (ft) | Elevation (ft) | Contour area (sqft) | Incr. Storage (cuft) | Total storage (cuft) |
|------------|----------------|---------------------|----------------------|----------------------|
| 0.00 | 297.00 | 70,300 | 0 | 0 |
| 1.00 | 298.00 | 72,800 | 71,550 | 71,550 |
| 2.00 | 299.00 | 75,400 | 74,100 | 145,650 |
| 3.00 | 300.00 | 78,100 | 76,750 | 222,400 |
| 4.00 | 301.00 | 80,800 | 79,450 | 301,850 |
| 5.00 | 302.00 | 83,600 | 82,200 | 384,050 |
| 6.00 | 303.00 | 86,400 | 85,000 | 469,050 |
| 7.00 | 304.00 | 89,200 | 87,800 | 556,850 |
| 8.00 | 305.00 | 92,100 | 90,650 | 647,500 |
| 9.00 | 306.00 | 95,000 | 93,550 | 741,050 |
| 10.00 | 307.00 | 98,000 | 96,500 | 837,550 |
| 11.00 | 308.00 | 101,000 | 99,500 | 937,050 |
| 12.00 | 309.00 | 104,100 | 102,550 | 1,039,600 |


Culvert / Orifice Structures

| | [A] | [B] | [C] | [PrfRsr] |
|-----------------|----------|------|------|----------|
| Rise (in) | = 36.00 | 0.00 | 0.00 | 0.00 |
| Span (in) | = 36.00 | 0.00 | 0.00 | 0.00 |
| No. Barrels | = 1 | 0 | 0 | 0 |
| Invert El. (ft) | = 304.80 | 0.00 | 0.00 | 0.00 |
| Length (ft) | = 41.00 | 0.00 | 0.00 | 0.00 |
| Slope (%) | = 0.60 | 0.00 | 0.00 | n/a |
| N-Value | = .013 | .013 | .013 | n/a |
| Orifice Coeff. | = 0.60 | 0.60 | 0.60 | 0.60 |
| Multi-Stage | = n/a | No | No | No |

Weir Structures

| | [A] | [B] | [C] | [D] |
|----------------|-----------------------|------|------|------|
| Crest Len (ft) | = 37.00 | 0.00 | 0.00 | 0.00 |
| Crest El. (ft) | = 306.40 | 0.00 | 0.00 | 0.00 |
| Weir Coeff. | = 2.60 | 3.33 | 3.33 | 3.33 |
| Weir Type | = Broad | --- | --- | --- |
| Multi-Stage | = No | No | No | No |
| Exfil.(in/hr) | = 0.000 (by Wet area) | | | |
| TW Elev. (ft) | = 0.00 | | | |

Note: Culvert/Orifice outflows are analyzed under inlet (ic) and outlet (oc) control. Weir risers checked for orifice conditions (ic) and submergence (s).



Hydrograph Report

Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2016 by Autodesk, Inc. v11

Monday, 04 / 9 / 2018

Hyd. No. 13


Fly Ash Pond Runoff

| | | | |
|-----------------|--------------|--------------------|----------------|
| Hydrograph type | = SCS Runoff | Peak discharge | = 146.18 cfs |
| Storm frequency | = 100 yrs | Time to peak | = 12.28 hrs |
| Time interval | = 1 min | Hyd. volume | = 715,373 cuft |
| Drainage area | = 32.000 ac | Curve number | = 81* |
| Basin Slope | = 1.0 % | Hydraulic length | = 1400 ft |
| Tc method | = LAG | Time of conc. (Tc) | = 40.38 min |
| Total precip. | = 8.44 in | Distribution | = Type II |
| Storm duration | = 24 hrs | Shape factor | = 484 |

* Composite (Area/CN) = [(3.000 x 100) + (29.000 x 79)] / 32.000

Fly Ash Pond Runoff

Hyd. No. 13 -- 100 Year



Hydrograph Report

Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2016 by Autodesk, Inc. v11


Monday, 04 / 9 / 2018

Hyd. No. 14

Fly Ash Pond

| | | | |
|-----------------|----------------------------|----------------|----------------|
| Hydrograph type | = Reservoir | Peak discharge | = 6.429 cfs |
| Storm frequency | = 100 yrs | Time to peak | = 16.17 hrs |
| Time interval | = 1 min | Hyd. volume | = 657,837 cuft |
| Inflow hyd. No. | = 13 - Fly Ash Pond Runoff | Max. Elevation | = 320.14 ft |
| Reservoir name | = Fly Ash Pond | Max. Storage | = 658,119 cuft |

Storage Indication method used. Wet pond routing start elevation = 316.70 ft.



Pond No. 4 - Fly Ash Pond

Pond Data

Contours -User-defined contour areas. Average end area method used for volume calculation. Beginning Elevation = 305.00 ft

Stage / Storage Table

| Stage (ft) | Elevation (ft) | Contour area (sqft) | Incr. Storage (cuft) | Total storage (cuft) |
|------------|----------------|---------------------|----------------------|----------------------|
| 0.00 | 305.00 | 00 | 0 | 0 |
| 1.00 | 306.00 | 11,148 | 5,574 | 5,574 |
| 2.00 | 307.00 | 11,148 | 11,148 | 16,722 |
| 3.00 | 308.00 | 11,148 | 11,148 | 27,870 |
| 4.00 | 309.00 | 11,148 | 11,148 | 39,018 |
| 5.00 | 310.00 | 11,148 | 11,148 | 50,166 |
| 6.00 | 311.00 | 11,148 | 11,148 | 61,314 |
| 7.00 | 312.00 | 11,148 | 11,148 | 72,462 |
| 8.00 | 313.00 | 11,148 | 11,148 | 83,610 |
| 9.00 | 314.00 | 11,148 | 11,148 | 94,758 |
| 10.00 | 315.00 | 11,148 | 11,148 | 105,906 |
| 11.00 | 316.00 | 11,148 | 11,148 | 117,054 |
| 12.00 | 317.00 | 119,729 | 65,439 | 182,493 |
| 13.00 | 318.00 | 38,875 | 79,302 | 261,795 |
| 14.00 | 319.00 | 65,883 | 52,379 | 314,174 |
| 15.00 | 320.00 | 499,611 | 282,747 | 596,921 |
| 16.00 | 321.00 | 385,012 | 442,312 | 1,039,232 |
| 17.00 | 322.00 | 128,757 | 256,885 | 1,296,117 |


Culvert / Orifice Structures

| | [A] | [B] | [C] | [PrfRsr] |
|-----------------|----------|------|------|----------|
| Rise (in) | = 24.00 | 0.00 | 0.00 | 0.00 |
| Span (in) | = 24.00 | 0.00 | 0.00 | 0.00 |
| No. Barrels | = 1 | 0 | 0 | 0 |
| Invert El. (ft) | = 316.75 | 0.00 | 0.00 | 0.00 |
| Length (ft) | = 916.00 | 0.00 | 0.00 | 0.00 |
| Slope (%) | = 0.11 | 0.00 | 0.00 | n/a |
| N-Value | = .023 | .013 | .013 | n/a |
| Orifice Coeff. | = 0.60 | 0.60 | 0.60 | 0.60 |
| Multi-Stage | = n/a | No | No | No |

Weir Structures

| | [A] | [B] | [C] | [D] |
|----------------|---------|---------------|------|------|
| Crest Len (ft) | = 0.00 | 0.00 | 0.00 | 0.00 |
| Crest El. (ft) | = 0.00 | 0.00 | 0.00 | 0.00 |
| Weir Coeff. | = 3.33 | 3.33 | 3.33 | 3.33 |
| Weir Type | = --- | --- | --- | --- |
| Multi-Stage | = No | No | No | No |
| Exfil.(in/hr) | = 0.000 | (by Wet area) | | |
| TW Elev. (ft) | = 0.00 | | | |

Note: Culvert/Orifice outflows are analyzed under inlet (ic) and outlet (oc) control. Weir risers checked for orifice conditions (ic) and submergence (s).



Hydrograph Report

Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2016 by Autodesk, Inc. v11

Monday, 04 / 9 / 2018


Hyd. No. 15

Process Pond Inflow

| | | | |
|-----------------|----------------------|----------------------|------------------|
| Hydrograph type | = Combine | Peak discharge | = 207.24 cfs |
| Storm frequency | = 100 yrs | Time to peak | = 11.97 hrs |
| Time interval | = 1 min | Hyd. volume | = 1,938,719 cuft |
| Inflow hyds. | = 4, 5, 6, 8, 12, 14 | Contrib. drain. area | = 33.590 ac |

Process Pond Inflow

Hyd. No. 15 -- 100 Year



Hydrograph Report

Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2016 by Autodesk, Inc. v11

Monday, 04 / 9 / 2018

Hyd. No. 16


Process Waste Pond

| | | | |
|-----------------|----------------------------|----------------|------------------|
| Hydrograph type | = Reservoir | Peak discharge | = 18.33 cfs |
| Storm frequency | = 100 yrs | Time to peak | = 17.75 hrs |
| Time interval | = 1 min | Hyd. volume | = 1,666,155 cuft |
| Inflow hyd. No. | = 15 - Process Pond Inflow | Max. Elevation | = 305.46 ft |
| Reservoir name | = Process Waste Pond | Max. Storage | = 3,206,778 cuft |

Storage Indication method used. Wet pond routing start elevation = 303.80 ft.

Process Waste Pond

Hyd. No. 16 -- 100 Year



Pond No. 2 - Process Waste Pond

Pond Data

Contours -User-defined contour areas. Average end area method used for volume calculation. Beginning Elevation = 297.00 ft

Stage / Storage Table

| Stage (ft) | Elevation (ft) | Contour area (sqft) | Incr. Storage (cuft) | Total storage (cuft) |
|------------|----------------|---------------------|----------------------|----------------------|
| 0.00 | 297.00 | 356,500 | 0 | 0 |
| 1.00 | 298.00 | 361,700 | 359,100 | 359,100 |
| 2.00 | 299.00 | 367,000 | 364,350 | 723,450 |
| 3.00 | 300.00 | 372,400 | 369,700 | 1,093,150 |
| 4.00 | 301.00 | 377,700 | 375,050 | 1,468,200 |
| 5.00 | 302.00 | 383,100 | 380,400 | 1,848,600 |
| 6.00 | 303.00 | 388,600 | 385,850 | 2,234,450 |
| 7.00 | 304.00 | 394,000 | 391,300 | 2,625,750 |
| 8.00 | 305.00 | 399,500 | 396,750 | 3,022,500 |
| 9.00 | 306.00 | 405,000 | 402,250 | 3,424,750 |
| 10.00 | 307.00 | 410,500 | 407,750 | 3,832,500 |
| 11.00 | 308.00 | 416,100 | 413,300 | 4,245,800 |
| 12.00 | 309.00 | 421,700 | 418,900 | 4,664,700 |


Culvert / Orifice Structures

| | [A] | [B] | [C] | [PrfRsr] |
|-----------------|----------|------|------|----------|
| Rise (in) | = 24.00 | 0.00 | 0.00 | 0.00 |
| Span (in) | = 24.00 | 0.00 | 0.00 | 0.00 |
| No. Barrels | = 1 | 0 | 0 | 0 |
| Invert El. (ft) | = 301.44 | 0.00 | 0.00 | 0.00 |
| Length (ft) | = 230.00 | 0.00 | 0.00 | 0.00 |
| Slope (%) | = 0.50 | 0.00 | 0.00 | n/a |
| N-Value | = .013 | .013 | .013 | n/a |
| Orifice Coeff. | = 0.60 | 0.60 | 0.60 | 0.60 |
| Multi-Stage | = n/a | No | No | No |

Weir Structures

| | [A] | [B] | [C] | [D] |
|----------------|-----------------------|------|------|------|
| Crest Len (ft) | = 3.00 | 0.00 | 0.00 | 0.00 |
| Crest El. (ft) | = 303.80 | 0.00 | 0.00 | 0.00 |
| Weir Coeff. | = 3.33 | 3.33 | 3.33 | 3.33 |
| Weir Type | = Rect | --- | --- | --- |
| Multi-Stage | = Yes | No | No | No |
| Exfil.(in/hr) | = 0.000 (by Wet area) | | | |
| TW Elev. (ft) | = 0.00 | | | |

Note: Culvert/Orifice outflows are analyzed under inlet (ic) and outlet (oc) control. Weir risers checked for orifice conditions (ic) and submergence (s).



| | |
|---|----------|
| Watershed Model Schematic..... | 1 |
| | |
| 100 - Year | |
| Summary Report..... | 2 |
| Hydrograph Reports..... | 3 |
| Hydrograph No. 1, Rational, Ash Handling, Oil Sep., and Boiler Tank Inflow..... | 3 |
| Hydrograph No. 2, SCS Runoff, Bottom Ash Pond Runoff..... | 4 |
| Hydrograph No. 3, Combine, Combined Bottom Ash Flows..... | 5 |
| Hydrograph No. 4, Reservoir, Bottom Ash Pond..... | 6 |
| Pond Report - Bottom Ash Pond..... | 7 |
| Hydrograph No. 5, SCS Runoff, Process Pond Runoff..... | 8 |
| Hydrograph No. 6, Rational, Demineralizer Inflow..... | 9 |
| Hydrograph No. 7, SCS Runoff, Coal Pile Runoff Settling Pond..... | 10 |
| Hydrograph No. 8, SCS Runoff, Coal Pile Runoff..... | 11 |
| Hydrograph No. 9, Rational, Coal Handling Washdown Inflow..... | 12 |
| Hydrograph No. 10, SCS Runoff, Settling Pond Runoff..... | 13 |
| Hydrograph No. 11, Combine, Settling Pond Inflow..... | 14 |
| Hydrograph No. 12, Reservoir, Settling Pond..... | 15 |
| Pond Report - Settling Pond..... | 16 |
| Hydrograph No. 13, SCS Runoff, Fly Ash Pond Runoff..... | 17 |
| Hydrograph No. 14, Reservoir, Fly Ash Pond..... | 18 |
| Pond Report - Fly Ash Pond..... | 19 |
| Hydrograph No. 15, Combine, Process Pond Inflow..... | 20 |
| Hydrograph No. 16, Reservoir, Process Waste Pond..... | 21 |
| Pond Report - Process Waste Pond..... | 22 |